

PERS-6



FBIS-6470-88
9 December 1988

MEMORANDUM FOR: Safety Division, OMS
FROM: FBIS Safety Officer
SUBJECT: Emergency Lighting

STAT
STAT

Per discussion with [redacted] this date, I am attaching the request for safety lights in the three vestibules leading into/from our Data Center, which is manned 24-hours.

STAT

[redacted] OL/RECD, feels the need for safety lights is not there. He feels that when the door is opened there will be adequate light from inside the vault. I have personally toured the area in question.

STAT

The entrance in [redacted] has a light, but not an emergency light.

STAT

The entrance in [redacted] has a light, but not an emergency light.

The entrance in [redacted] has no light.

I recommend this request be approved and that the two existing lights be changed to emergency light status. The one area that has no lights should be so equipped. This will assure adequate lighting between two steel vault doors in the event that the power inside the data center, or out in the hallway is off.

Your guidance in this area will be appreciated.

STAT

Attachment:
Request as stated